

CONSEJO NACIONAL DE OPERACIÓN CNO

ANEXO 2 CONFIGURACIONES TEBSA



CONSEJO NACIONAL DE OPERACIÓN CNO

Planta: TEBSA

Fecha de aplicación: Operación Agosto 01 de 2009

CONFIGURACIÓN	MÍNIMO TÉCNICO (MW)	RANGO DE DISPONIBILIDAD		UNIDADES INDISPONIBLES		
		MÍNIMO	MÁXIMO	GT 110	GT 220	ST
1	120	0	791	0	0	0
2	153	0	791	0	0	0
3	234	0	791	0	0	0
4	312	0	791	0	0	0
5	392	0	791	0	0	0
6	120	0	642	1	0	0
7	153	0	642	1	0	0
8	234	0	642	1	0	0
9	312	0	642	1	0	0
10	120	0	642	0	1	0
11	153	0	642	0	1	0
12	234	0	642	0	1	0
13	312	0	642	0	1	0
14	120	0	624	0	0	1
15	153	0	624	0	0	1
16	234	0	624	0	0	1
17	283	0	624	0	0	1
18	333	0	624	0	0	1
19	120	0	530	1	0	1
20	153	0	530	1	0	1
21	234	0	530	1	0	1
22	283	0	530	1	0	1
23	120	0	530	0	1	1
24	153	0	530	0	1	1
25	234	0	530	0	1	1
26	283	0	530	0	1	1
27	120	0	464	0	0	2
28	144	0	464	0	0	2
29	194	0	464	0	0	2
30	244	0	464	0	0	2
31	120	0	436	2	0	1
32	153	0	436	2	0	1
33	234	0	436	2	0	1
34	120	0	436	1	1	1
35	153	0	436	1	1	1
36	234	0	436	1	1	1
37	120	0	436	0	2	1

CONSEJO NACIONAL DE OPERACIÓN CNO

38	153	0	436	0	2	1
39	234	0	436	0	2	1
40	120	0	370	1	0	2
41	144	0	370	1	0	2
42	194	0	370	1	0	2
43	120	0	370	0	1	2
44	144	0	370	0	1	2
45	194	0	370	0	1	2
46	120	0	319	2	1	1
47	153	0	319	2	1	1
48	120	0	319	1	2	1
49	153	0	319	1	2	1
50	120	0	319	0	3	1
51	153	0	319	0	3	1
52	120	0	276	2	0	2
53	144	0	276	2	0	2
54	120	0	276	1	1	2
55	144	0	276	1	1	2
56	120	0	276	0	2	2
57	144	0	276	0	2	2
58	120	0	182	2	1	2
59	120	0	182	1	2	2
60	120	0	182	0	3	2
61	120	0	156	2	2	1
62	120	0	156	1	3	1