

GPM PPC – certificate

Fundación

Date: 2024-03-08

Modified: 2024-03-08

Prepared by

Name:	Xavier Gironès
Job Title:	SCADA Project Manager
Email:	xavier.girones@greenpowermonitor.com

Distribution

- ☐ OPEN. Unrestricted distribution, internal and external.
- ☒ INTERNAL use only. Internal GPM document.
- ☒ CONFIDENTIAL. Distribution within GPM according or applicable contract. *
- ☐ SECRET. Authorized access only.


*Specify distribution: with client

1 CERTIFICATE FOR GPM PPC

This is to certify the parameters configured in the Power Plant Controller (PPC) implemented and tested in the renewable solar plant of **FUNDACIÓN**, in Colombia, managed by ENEL Green Power.

Please see below in the table the parameters defined:

Parameter	Range		Current Settings
	Minimum	Maximum	
Primary Voltage Statism [%]	4%	24%	8%
Primary Voltage regulation Deadband [V]	0 V	1,2 V	0 V
Primary Frecuency Statism [%]	1%	7%	4%
Primary Frecuency regulation Deadband [mHz]	0 mHz	150 mHz	30 mHz
Active power ramp [kW/min]	5.000 kW/min	15.000 kW/min	12.600 kW/min



Xavier Gironès
 SCADA Project Manager